



CITY OF WASHINGTON, ILLINOIS
City Council Agenda Communication

Meeting Date: Monday October 17th, 2022

Prepared By: Brian Rittenhouse – Public Works Director

Agenda Item: Oakwood Storm Sewer CIPP Lining Purchase Authorization.

Explanation: Over the years Staff has addressed sinkholes along a 300 ft. 42-inch corrugated metal Storm Sewer at the intersection of Oakwood and Eilers Ct. The metal pipe has rusted away in spots causing the sinkholes. Staff received a quote of \$174,500.00 from Hoerr for CIPP lining. Hoerr was awarded the City's CIPP Lining commodities bid. Staff was told, by GA Rich, it would cost a lot more to open cut because it would involve trenching through curb, roads and yards. This is a budgeted storm sewer project.

Fiscal Impact: Not-to-exceed the budgeted \$175,000.00 for the Storm Sewer CIPP Lining.

Staff Recommendations: Staff recommends contracting Hoerr Construction to perform the Oakwood Storm Sewer CIPP Lining.

Action Requested: Approve purchase authorization to contract Hoerr Construction to perform the Oakwood Storm Sewer CIPP Lining in not-to-exceed amount of \$175,000.00.

